



NFPA 99 TEST RECORD
PATIENT CARE AREAS

LOCATION OF TEST: _____

TEST INSTRUMENT/MODEL #: _____ DATE CALIBRATED: _____

ROOM # _____ DEPT. _____ DATE TESTED: _____

NFPA 99 4.3.3.1.2

REFERENCE POINT (1)____(2)____(3)____

TEST VOLTAGE _____ mV FULL SCALE

TEST RESISTANCE _____ OHMS FULL SCALE

Table with 4 columns: LOCATION, mV 4.3.3.1.3, OHMS 4.3.3.1.4, and test results for METAL SURFACE and RECEPTACLE LOCATION.

NFPA 99 4.3.3.2 RECEPTACLE TEST RESULTS

NFPA 99 4.3.3.2.1 PHYSICAL INTEGRITY IS GOOD _____ YES _____ NO

NFPA 99 4.3.3.2.2 GROUNDING CIRCUIT IS VERIFIED _____ YES _____ NO

NFPA 99 4.3.3.2.3 POLARITY IS CORRECT _____ YES _____ NO

NFPA 99 4.3.3.2.4 RETENTION FORCE IS GREATER THAN 4 OZ. _____ YES _____ NO

LIM TESTS PER NFPA 99 4.3.3.3.2.1 APPLICABLE? _____ YES _____ NO

LIM TESTS PER NFPA 99 4.3.4.1.4 APPLICABLE? _____ YES _____ NO

LIM TESTS PER NFPA 99 4.3.4.1.5 APPLICABLE? _____ YES _____ NO

RESULTS OF LIM TESTS IF APPLICABLE

VOLTAGE OF TEST _____ RESISTOR OHMS V x 200 _____

RESULTS OF INITIAL INSTALLATION TESTS:

ADDITIONAL COMMENTS:

SIGNED: _____ DATE: _____

NEI ELECTRIC, INC.