



NFPA 99 TEST RECORD
PATIENT CARE AREAS

LOCATION OF TEST: \_\_\_\_\_

TEST INSTRUMENT/MODEL #: \_\_\_\_\_ DATE CALIBRATED: \_\_\_\_\_

ROOM # \_\_\_\_\_ DEPT. \_\_\_\_\_ DATE TESTED: \_\_\_\_\_

NFPA 99 4.3.3.1.2

REFERENCE POINT (1)\_\_\_\_(2)\_\_\_\_(3)\_\_\_\_

TEST VOLTAGE \_\_\_\_\_ mV FULL SCALE

TEST RESISTANCE \_\_\_\_\_ OHMS FULL SCALE

Table with columns: LOCATION, mV 4.3.3.1.3, OHMS 4.3.3.1.4. Rows include METAL SURFACE and RECEPTACLE LOCATION.

NFPA 99 4.3.3.2 RECEPTACLE TEST RESULTS

NFPA 99 4.3.3.2.1 PHYSICAL INTEGRITY IS GOOD \_\_\_\_\_ YES \_\_\_\_\_ NO

NFPA 99 4.3.3.2.2 GROUNDING CIRCUIT IS VERIFIED \_\_\_\_\_ YES \_\_\_\_\_ NO

NFPA 99 4.3.3.2.3 POLARITY IS CORRECT \_\_\_\_\_ YES \_\_\_\_\_ NO

NFPA 99 4.3.3.2.4 RETENTION FORCE IS GREATER THAN 4 OZ. \_\_\_\_\_ YES \_\_\_\_\_ NO

LIM TESTS PER NFPA 99 4.3.3.3.2.1 APPLICABLE? \_\_\_\_\_ YES \_\_\_\_\_ NO

LIM TESTS PER NFPA 99 4.3.4.1.4 APPLICABLE? \_\_\_\_\_ YES \_\_\_\_\_ NO

LIM TESTS PER NFPA 99 4.3.4.1.5 APPLICABLE? \_\_\_\_\_ YES \_\_\_\_\_ NO

RESULTS OF LIM TESTS IF APPLICABLE

VOLTAGE OF TEST \_\_\_\_\_ RESISTOR OHMS V x 200 \_\_\_\_\_

RESULTS OF INITIAL INSTALLATION TESTS:

\_\_\_\_\_

ADDITIONAL COMMENTS:

\_\_\_\_\_

SIGNED: \_\_\_\_\_ DATE: \_\_\_\_\_

NEI ELECTRIC, INC.